



Robert W. Muller
Mayor

Douglas A. Remaley
Commissioner

George Farah, III
Mayor Pro Tem

Town of Nags Head

Post Office Box 99
Nags Head, North Carolina 27959
Telephone (252) 441-5508
FAX (252) 441-0776
www.townofnagshead.net

R. Brantley Murray
Commissioner

J. Webb Fuller
Town Manager

Anna D. Sadler
Commissioner

Board of Commissioners Policy

Concrete Sidewalk Standards

(Adoption Date: February 5, 1990)
(Updated: June 4, 2003)

1. Concrete slab to be 5 feet wide by 6 inches thick, 4,000 psi per cubic yard mix. Concrete plant must submit a mix for design approval prior to construction.
2. Concrete to contain "fibermesh" fiberglass reinforcement.
3. Provide expansion joints at each driveway connection and at 50 foot intervals between drives. Score slab 1 ½ inches deep at 5 foot intervals.
4. Concrete must be poured with a maximum slump of 6 inches. This will be tested by Town personnel in the field prior to placing concrete.
5. A curing compound is to be applied after placing concrete.